

NOTE : PRESSURE HOLDING TIME = 05 SECOND MINIMUM

1 Mpa = 10 bar

Tolerances : -

1) Outside Diameter of Body & Ends:

Specified Outside Diameter D mm(in)	Body Tolerances mm(in)	Ends Tolerances mm(in)	Out-of-roundness tolerances mm(in)	
			Pipe except the end	Pipe end
< 60.3 (2.375)	- 0.8 (0.031) to + 0.4 (0.016)	- 0.8 (0.031) to + 0.4 (0.016)	1.2 (0.048)	0.9 (0.036)
≥ 60.3 (2.375) to 168.3 (6.625)	±0.0075 D	-0.4 (0.016) to+ 1.6 (0.063)	0.020 D for D/t ≤ 75	0.015 D For D/t ≤ 75
> 168.3(6.625) to 610 (24.000)	± 0.0075 D, but maximum of ±3.2 (0.125)	± 0.005 D, but maximum of ± 1.6 (0.063)	0.020 D	0.015 D

2) Thickness Tolerances mm(in)

≤ 5.0(0.197) = ±0.5 (0.020)	a) for pipe in grade A25 = + 10.0 %, - 5.0 % of nominal mass
> 5.0(0.197) to < 15.0(0.591) = ± 0.1t	b) for all other pipes = +10.0 %, - 3.5 % of nominal mass
(where t = wall thickness)	c) mass of 18 tonnes or more for all other grade = -1.75 %

3) Mass Tolerances :

Mechanical Properties(Tensile):

PSL 1 Pipe	Gr. A or L210	Gr. B or L245	Gr. X42 or L290	Gr. X46 or L320	Gr. X52 or L360	Gr. X56 or L390	Gr. X60 or L415	Gr. X65 or L450	Gr. X70 or L485
Yield Strength MPa (min)	210	245	290	320	360	390	415	450	485
Tensile Strength MPa (min)	335	415	415	435	460	490	520	535	570
Elongation % minimum	Min .Elong. shall be determined by $A_f = 1940 A^{0.2} / U^{0.9}$ (Where A= Area of test specimen, U= Min. specified tensile strength)								
PSL 2 Pipe	Gr. B or L245	Gr. X42 or L290	Gr. X46 or L320	Gr. X52 or L360	Gr. X56 or L390	Gr. X60 or L415	Gr. X65 or L450	Gr. X70 or L485	Gr. X80 or L555
Yield Strength MPa (min)	245 - 450 ^e	290 - 495	320-525	360 - 530	390 - 545	415 - 565	450 - 600	485 - 635	555 - 705
Tensile Strength MPa (min)	415 - 655	415 - 655	435 - 655	460 - 760	490 - 760	520 - 760	535 - 760	570 - 760	625 - 825
Elongation % minimum	Min .Elong. shall be determined by $A_f = 1940 A^{0.2} / U^{0.9}$ (Where A= Area of test specimen, U= Min. specified tensile strength)								
Ratio (YS/TS) Max.	0.93								

e= For pipe requiring longitudinal testing, the maximum yield strength shall be ≤ 495 Mpa

Chemical Properties : Composition (Max.%)

PSL 1	C	Mn	P	S	Cu	Ni	Cr	Mo	V+Nb Nb+V+Ti	Nb + V + Ti				
Grade A or L210	0.22	0.90	0.030	0.030	0.50	0.50	0.50	0.15	--					
Grade B or L245	0.26	1.20	0.030	0.030	0.50	0.50	0.50	0.15	≤ 0.06	≤ 0.15				
Grade X42 or L290	0.26	1.30	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X46 or L320	0.26	1.40	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X52 or L360	0.26	1.40	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X56 or L390	0.26	1.40	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X60 or L415	0.26	1.40	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X65 or L450	0.26	1.45	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
Grade X70 or L485	0.26	1.65	0.030	0.030	0.50	0.50	0.50	0.15	--	≤ 0.15				
PSL 2	C	Si	Mn	P	S	V	Nb	Ti	Cu	Ni	Cr	Mo	CE _{iw}	CE _{pcm}
Grade B or L245	0.22	0.45	1.20	0.025	0.015	0.05	0.05	0.04	0.50	0.30	0.30	0.15	0.43	0.25
Grade X42 or L290	0.22	0.45	1.30	0.025	0.015	0.05	0.05	0.04	0.50	0.30	0.30	0.15	0.43	0.25
Grade X46 or L320	0.22	0.45	1.30	0.025	0.015	0.05	0.05	0.04	0.50	0.30	0.30	0.15	0.43	0.25
Grade X52 or L360	0.22	0.45	1.40	0.025	0.015		≤ 0.15		0.50	0.30	0.30	0.15	0.43	0.25
Grade X56 or L390	0.22	0.45	1.40	0.025	0.015		≤ 0.15		0.50	0.30	0.30	0.15	0.43	0.25
Grade X60 or L415	0.12	0.45	1.60	0.025	0.015		≤ 0.15		0.50	0.50	0.50	0.50	0.43	0.25
Grade X65 or L450	0.12	0.45	1.60	0.025	0.015		≤ 0.15		0.50	0.50	0.50	0.50	0.43	0.25
Grade X70 or L485	0.12	0.45	1.70	0.025	0.015		≤ 0.15		0.50	0.50	0.50	0.50	0.43	0.25
Grade X80 or L555	0.12	0.45	1.85	0.025	0.015		≤ 0.15		0.50	1.00	0.50	0.50	0.43	0.25

Destructive & Non-Destructive Testing

Hydrostatic testing: 100% of pipe shall be tested at a Pressure specified in above table.

NDT: Weld seam of each pipe shall be tested by online Eddy Current test and online automatic ultrasonic test.

- Flattening:**
- No opening of the weld before the distance between the plates is less than 50% of the original outside diameter.
 - There shall be no crack or break other than in the weld before the distance between the plates is less than 33% of the original outside diameter.
 - No evidence of lamination or burnt metal shall develop during the flattening until opposite wall of the pipe meet.

Metallography: Micro Structure and Micro Hardness (HV10) test are carried out.

Impact Testing: For Only PSL 2 pipes up to Grade X70 (at 0°C), Minimum average absorbed energy = 27 J, Minimum Individual absorbed energy = 21J

Marking: Stencilling as per the specification & customer requirement.